


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 764

Dated: 20/03/2025

It is certified that an inspection team headed by Sri HARI RAM
 (Name of Officers with designation) from Junior Engineer PHED Dist. sub. Div. Sikar
 (Name of Department/ Office) inspected the AKASHDEEP SHIKSHAN SANSTHAN SR. SEC SCHOOL
 (Name & Address of the school) on 18/03/2025 (date of inspection) and found that
 the AKASHDEEP SHIKSHAN SANSTHAN SR. SEC SCHOOL (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of ONE YEAR.....


 सचिव
 आकाशदीप शिक्षण संस्थान
 हर्ष रोड, साँवली (सीकर)

Signature with Seal: ✓


 जन स्वा.स.मि.विभाग
 जिला-उज्जैन, सीकर

Name

: HARI RAM

Designation

: Assistant EngineerName & Address of the Office / Department : PHED SIKAR

To

AKASHDEEP SHIKSHAN SANSTHAN
SR. SEC. SCHOOL HARSH ROAD SANWALI
SIKAR

(Name & Address of the Institution)



प्रधानाचार्य (1221225)
 आकाशदीप शिक्षण संस्थान उच्च मा. विद्यालय
 सालम सिंह की झण्डी, साँवली (सीकर)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.

**OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY SIKAR**

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Private Chem.Rep)/2024-2025/ **1078**

Not valid for legal case

Date - **24/03/2025**

To,

Principal
Aakashdeep Shikshan Sr. Sec.School
Salam Singh ki Dhani, Sanwali, Sikar (Raj.)

District: Sikar
Block : Dhod


Reference : Your Letter No-2274. Date 20.03.2025
Date of Receipt : 20.03.2025

Sample Collected by- Sh Manoj Kumar

Source			TW
Source Location	Permissible value as per B.I.S. 10500/2012		Aakashdeep Shikshan Sr. Sec.School Salam Singh ki Dhani, Sanwali, Sikar (Raj.)
Gram Panchayat			Sanwali
Village/Town/ City	Desirable limit	Permissible limit in absence of alternate Source	Salam Singh ki Dhani
Habitation			Salam Singh ki Dhani
Date of Collection			20.03.2025
Date of Examination			24.03.2025
Lab. Sample No.			1907

Note :- All results Except pH are in mg/L


pH	6.5 to 8.5	No Relaxation	7.51
Conductivity			1985
Total Alkalinity (as CaCO ₃)	200	600	370
Total Hardness (as CaCO ₃)	200	600	310
Chloride (as Cl ⁻)	250	1000	230
Nitrates (as NO ₃ ⁻)	45	45	23
Sulphate (as SO ₄ ⁻²)	200	400	---
Fluoride (as F ⁻)	1.0	1.5	0.38
Total Dissolved Solids	500	2000	1189


गोपाल लाल शर्मा
वरिष्ठ रसायनज्ञ
Senior Chemist
जन स्वास्थ्य अभियंत्रित्वी विभाग
PHED Lab Sikar
प्रयोगशाला, सीकर
Dated:


No. Lab/Tech(Private Chem.Rep)/2024-2025/

Copy to:

1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.


प्रधानाचार्य (1221225)
आकाशदीप शिक्षण संस्थान उच्च मा. विद्यालय
सालम सिंह की दानी, साँवली (सीकर)

Senior Chemist
PHED Lab Sikar


सचिव
आकाशदीप शिक्षण संस्थान
हर्य रोड, साँवली (सीकर)